

# Block Creek Aerobic Services, LLC

444 A Old Hwy No 9

Comfort, TX 78013

(830) 995-3189

Owner Phone: (512) 637-9200

Cell Phone: (512) 637-9200

**Richard & Tracey Sorenson**

**11400 Crumley Ranch Road**

**Austin, TX 78738**

Agency: Travis

County: Travis

**Site Address: 11400 Crumley Ranch Road, Austin Permit #:**

System Info: MFG: Advantage Wastewater LLC Brand: Nu Water

ID: 4653

Treatment Type: Aerobic With Chlorine

Disposal Type: Surface Application

Aerator S/N: 13757

Insp ID: 184068

Installed: 8/8/2016

Warranty Expiration: 8/8/2018

System S/N: B3470

Visit Details

**Visit Date: 10/8/2025**

**Entered By: roland**

GPS Lat: 30.25512 GPS Long: -98.025283

Scheduled Date: 10/12/2025

Contract Starts: 10/12/2025

Entered On: 10/8/2025

Contract Ends: 10/12/2026

Visit Results

**Service Type: Scheduled Inspection**

Printed: 10/8/2025

Count: Inspection 1 of 3

**Method: Grab**

License #

Expires

**Technician: Jason K Stanberry**

MP0002388

11/30/2027

**Provider: Rudy Carson**

MP0002036

11/30/2025

☒ Service Completed

**Aerators: Operational**

**Sludge Level Tank 1: 18**

**Filters: Operational**

**Sludge Level Tank 2: 0"**

**Irrigation Pumps: Operational**

**Sludge Level Tank 3: 0"**

**Disinfection Device: Operational**

**Chlorine Supply: Operational**

**Floats: OP**

**Chlorine Residual: .03**

**Timer: OP**

**Tank Lid / Riser: Secured**

**Electric Circuits: Operational**

**Distribution System: Operational**

**Drip/Sprayfield Veg: Operational**

**Alarm: Operational**

Comments

- Technician Secured the Tank Lid and/or Riser prior to leaving location. - Cleaned compressor filter - Scum in pretreatment is 12" sprinklers good alarms good floats where not zip tied. Tech pulled pump drained and cleaned pump filter and re zip tied floats. Floats are operational system is good - Secured system in the on position with a lock bolt tech added bleach per customer request

Provider:

*Rudy Carson*

Technician: Jason K Stanberry

License: Number: MP0002036 Exp: 11/30/2025

License: Number: MP0002388 Exp: 11/30/2027



# WORK ORDER

Block Creek Aerobic Services, LLC

444 A Old Hwy No 9

Comfort, TX 78013

Phone: (830) 995-3189

Area

Mapkey

Stop

0

WO Number	Customer ID	Opened	Time	Scheduled	Time	Served	Time	Closed
67392	4653	10/7/2025	12:10 PM	10/8/2025				
Customer Name and SITE Address				Contact		Customer Email Address		Warranty Ends
Richard & Tracey Sorenson 11400 Crumley Ranch Road Austin, TX 78738						rhsorenson@mac.com		8/8/2018
				MainPhone		Cell	Work / Ext	
				(512) 637-9200		(512) 637-9200		
						Alternate Phone		
System Permit #		Brand of System				Aerator Serial #		
		Nu Water				13757		
Work Order Type		Assigned Technician				HEALTH DEPT.		
Scheduled Inspection				Entered By		Travis		
				roland				
DESCRIPTION OF THE WORK ORDER (REASON FOR CALL)								

left vm try to go by to inspect

RESULTS OF THE WORK ORDER	CONTRACT STARTS
- Technician Secured the Tank Lid and/or Riser prior to leaving location. - Cleaned compressor filter - Scum in pretreatment is 12" sprinklers good alarms good floats where not zip tied. Tech pulled pump drained and cleaned pump filter and re zip tied floats. Floats are operational system is good - Secured system in the on position with a lock bolt tech added blach per customer request	10/12/2025
	CONTRACT ENDS
	10/12/2026
DIRECTIONS OR INSTRUCTIONS TO THE TECHNICIAN	NEXT INSPECTION
	2/12/2026

Gate code 3189

He does have dogs, they are friendly, new pup might be a bit rowdy but not dangerous

X

Signature for Richard & Tracey Sorenson

Service Date / Time

Technician's Signature

Block Creek Aerobic Services, LLC

444 A Old Hwy No 9

Comfort, TX 78013

Entered By: roland

GPS La: 30.25512  
GPS Lo: -98.025283

Entered on  
10/7/2025

Name: Richard & Tracey Sorenson - ID #: 4653

Site: 11400 Crumley Ranch Road, Austin, TX 78738

WO #:	67392
Type:	Scheduled Inspe
Opened:	10/7/2025
Served:	
Closed:	